

§ 82.13.060 FS1, FS2, and FS3 Development Standards

Spark Arresters. Each chimney used in conjunction with a fireplace, or other heating appliance in which solid or liquid fuel is used, shall be maintained with a spark arrester. An approved spark arrester shall mean a device constructed of stainless steel, copper or brass, woven galvanized wire mesh, 12 gauge minimum of three-eighths inch minimum to one-half inch maximum openings, mounted in or over all outside flue openings in a vertical and near vertical position, adequately supported to prevent movement and visible from the ground.

Fuel Tanks. Fuel tanks (e.g., liquefied petroleum tanks) shall be located at least ten feet away from any structure and shall be in compliance with the standards in the Uniform Fire Code, § [83.02.080](#) (Allowed Projections into Setbacks), and § [83.01.060](#) (Fire Hazards). The tanks shall be secured to the ground.

CHAPTER 5: PUBLIC NUISANCE ABATEMENT FOR HAZARDOUS MATERIALS

 § 23.0502 **Definitions.**

Definitions stated in other Chapters of this Code shall supplement the following:

PUBLIC NUISANCES include:

- (a) Accumulations of junk, trash, and related materials as set forth more specifically at [Chapter 8 of Division 3 of Title 3](#) of the San Bernardino County Code (Waste Management) herein and including but not limited to: scrap metals; scrap plastic or polymer materials; scrap pipe or plumbing fixtures; machinery; rags; bedding; waste oil; batteries; oily wastes and similar accumulations under conditions not in compliance with approved land uses or locations as set forth more specifically in Title 8 of the San Bernardino County Code (Development), or otherwise in any manner detrimental to public health and safety or the environment.